



ASHRAE CHENNAI CHAPTER

NEWS LETTER

(bi-monthly)

(for private circulation only)

Issue No. 4

June & July - 2018 Issue

Committee Members (2017-18)

President:

Mr. Mansoor J Bhavnagarwala - 9840127879

President-Elect:

Mr. Sridhar Vijayaraghavan - 98401 09641

Vice President:

Dr. Swaminathan Jose

Past President & GGAC:

Dr. Prakash Maiya - 9444079546

BOG & COMMITTEE Members:

Secretary:

Vijayabhaskaran Subbiah - 9840977786

Treasurer:

Mr. Ramalingam Balaji - 9543666002

Mr. Duraisamy Balakrishnan

Chapter Administrator

Dr. R. Saravanan

Chair Refrigeration

Mr. CibiChakravarthy

Chair Student Activities

Mr. Mahadevan Sriram

Chair CTTC

Mr. Sayani Haribabu

Chair Membership Promotion

Mr. Rasheed Salman

Chair Sustainability

Mr. Subburaj Rajesh

Chair YEA

Mr. Rathinam Jaganraj

Co-chair YEA

Mr. S Vidyasagar

Historian

Mr. SankaranJanakiraman

Chair Attendance Committee

Mr. K. Sajeesh Kumar

Electronic Sub Committee Member

Mr. Ashok Kumar S


Sub Committee Member

Mr. Neethimohan .V


Sub Committee Member

Mr. Hariprasad I

Sub Committee Member



ASHRAE CHENNAI CHAPTER ACTIVITIES



Ashrae Summer Conference and RAL Meet @ Houston Mr. Sayani Haribabu (MP Chair) participated from Chennai Chapter on 24 thJune 2018

India HVAC Market to Reach USD3.97 Billion by 2019.

HVAC systems are becoming one of the key building blocks in modern infrastructure. These systems are found in almost all upcoming commercial as well as residential buildings. Rise in infrastructure, rapid urbanization and growth in commercial properties are some of the key factors fuelling the market for HVAC systems in India. With healthy growth anticipated in the real estate sector, the country is expected to witness strong infrastructure development, which would boost the market for HVAC systems over the next five years.

According to the recently published report by TechSci Research, “**India HVAC Market Forecast and Opportunities, 2019**”, the HVAC market in India is forecast to reach USD3.97 billion by 2019. Growth in retail, hospitality and commercial sectors is significantly boosting the demand for such systems in the country, as these sectors involve large-scale application of HVAC systems in organized retail outlets, shopping complexes, hotels, etc. Moreover, with anticipated growth in FDI (Foreign Direct Investment), several international players are expected to enter and start operations in the Indian retail market. Driven by strong FDI inflow from multinational food processing companies, the retail market in India is projected to reach USD726.62 billion by 2019, which is expected to further fuel the country's HVAC market.

The room air conditioning segment captured majority revenue share in India HVAC market in 2013, and is expected to retain its dominance by 2019. This is largely due to portability; ease of installation and less space requirement of room air conditioning systems. Centralized air conditioners, in contrast, are comparatively costlier and are usually preferred for large commercial or office spaces, where more tons of refrigeration is required for effective cooling. Consequently, segment share of room air conditioners in the India HVAC market is expected to increase over the next five years on account of several residential projects coming up in the forthcoming years.

“The Northern region has been leading the HVAC market in India, with high revenue contribution

from Delhi-NCR. In 2013, real estate market in Delhi-NCR grew by 22.5%, leading to high growth in the HVAC market, in volume as well as value terms. Rapid infrastructure development activities have been witnessed in cities such as Gurgaon, Noida, Greater Noida and Chandigarh in recent year. Further growth in real estate sector in these cities is expected to spur the market for HVAC systems in Northern India”, said Mr. Karan Chechi, Research Director with TechSci Research, a research based global management consulting firm.

“**India HVAC Market Forecast and Opportunities, 2019**” has evaluated the future growth potential of the HVAC market in India and provides statistics and information on market structure, market trends, market size & share, etc. The report includes HVAC market projections and demand forecasting. The report is intended to provide cutting-edge market intelligence and help decision makers take sound investment evaluation. Besides, the report also identifies and analyses the emerging trends along with essential drivers, challenges and opportunities available in the HVAC market in India.

FUTURE OF HVAC INDUSTRY WITH EMERGENCE OF GREEN BUILDING IN INDIA

It seems the era of “Green Building” has brought with it a trend in HVAC design, where the new technologies and strategies are adopted to achieve higher energy performance. Our definition of green buildings inevitably extends beyond the concerns of HVAC designers alone since the very concept places an emphasis on the integration of mechanical, electrical architectural, public health engineering, and other systems. Green building is one that achieves high performance, over the full life cycle, in the following areas:

- Minimal consumption of energy- due to reduction of need and more efficient utilization of non renewable natural resources, land, water, and other materials as well.

- Minimal atmospheric emissions having negative environmental impacts, especially those related to greenhouse gases (GHG), global warming, particulates, or acid rain.
- Minimal discharge of harmful liquid effluents and solid wastes, including those resulting from the ultimate demolition of the building itself at the end of its useful life.
- Minimal negative impacts on site ecosystems.
- Maximum quality of indoor environment, including air quality, thermal regime, illumination, acoustics/noise, and visual aspects.

HVAC designer plays an important role in the functionality of a green building. The HVAC system for green building shall be designed to reduce energy consumption while maintaining the interior conditions at a comfortable level to keep occupants health & productivity. The designer should ensure the HVAC system design NOT only meet the standard on energy front but beat the standard codes like Energy Conservation Building Codes (ECBC), India & American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) standards to achieve higher level of green building LEED (Leadership in Energy and Environmental Design) rating. Noticeable Changes in the recent and future HVAC Industry due to Green Building Construction:

(1) Chiller Selection: All the major HVAC equipments like Chillers and Packaged AC units are procured based on their energy performance rating to beat the energy rating specified in ECBC and ASHRAE standard. This is in order to score more points under Green Building LEED Rating Energy & Atmosphere Credit 1.1. As it has become mandatory to achieve 14% (2 points) under Energy category in LEED Green Building Rating System for Core & Shell project to meet the certification eligibility.

(2) Ancillary HVAC Equipment Selection: Pump and fan capacities can be reduced and energy saved by using variable speed drives to control their speed. Reductions in both peak and off-peak energy costs can be obtained by using variable speed drives on pumps, fans and compressors that operate at varying loads.

(3) Outdoor Air Delivery System: Optimization on fresh air supply to the occupied space as per ASHRAE 62.1-2004 to ensure the system neither over ventilates nor under ventilates the building. The concept of implementing Dedicated Outdoor Ventilation (DOAS) & Demand Control Ventilation (DCV) system are becoming popular to ensure the right amount building ventilation to strike a balance between human discomfort due to under ventilation and energy loss due to over ventilation.

(4) Supply Air System Control: Using Variable Air Volume boxes and dedicated individual control for 50% of the occupied people / all closed cabins in the occupied area will become mandatory to ensure human comfort & energy saving benefit.

(5) Indoor Air Quality (IAQ) Monitoring: In order to maintain the IAQ of the occupied area, it is required to install a Fresh air system which Controls, Measures, Monitors continuously the flow of fresh air (Outdoor air) supplied to the occupied area. The CO₂ Sensors installed in the occupied areas to ensure proper Indoor Air Quality. The fresh air flow & CO₂ level information is fed to Building Automation System (BAS) to trigger corrective action, if applicable.

(6) Energy Conservation Measure (ECM) Strategies in HVAC System: Adopting various energy conservation measures on HVAC system after conducting thorough Life Cycle Cost Analysis (LCCS) of ECM strategies to save energy.

ECM 1: Demand Control Ventilation (DCV) using CO2 Sensors:

A significant component of indoor environmental quality is the indoor air quality (IAQ), ASHRAE Standard 62-2001 describes in detail the ventilation required to provide a healthy environment. However, providing ventilation based strictly on the peak occupancy using the Ventilation Rate Procedure will result in over ventilation during periods. Any positive impact on IAQ brought on by over ventilation will be outweighed by the costs associated with the energy required to condition the ventilation air. CO2 sensor can be used to measure or control the per person ventilation rate and, in turn, allow the designer to introduce a ventilation demand control strategy.

ECM 2: Dedicated Outdoor Air Systems (DOAS):

A DOAS uses a separate air handler to condition the outdoor air before delivering it directly to the occupied spaces. While a DOAS can be applied in any design, it is most beneficial in a facility with multiple spaces with differing ventilation needs. A DOAS ensures compliance with ASHRAE 62-1999 for proper multiple space ventilation and adequate IAQ. It reduces a building's energy use when compared to mixed air systems that requires over ventilation of some spaces. It allows the designer to decouple the latent load from the sensible load, hence providing more accurate space humidity control. It allows easy airflow measurement and balance, and keeps ventilation loads off main HVAC units.

ECM 3: Air to Air Heat Recovery System:

A heat exchange enthalpy wheels can be used in comfort application, where energy in the exhaust stream would otherwise be wasted. Energy recovery is most economical when there are large temperature differences between the airstreams, the source of supply is close to the exhaust, and they are both relatively constant throughout the year. With a total energy wheel, the humidification costs may be reduced in cold weather and dehumidification costs may be lowered in warm weather.

ECM 4: Consider Variable Speed Drives for Pumps, Fans & Compressors:

Pump and fan capacities can be reduced and energy saved by using variable speed drives to Pump and fan capacities can be reduced and energy saved by using variable speed drives to control their speed. Reductions in both peak and off-peak energy costs can be obtained by using variable speed drives on pumps, fans and compressors that operate at varying loads. They pay off better if the systems they are applied to operate at part load for relatively long hours. Variable speed pumping can dramatically increase energy savings, particularly when it is combined with demand-based pressure reset controls. Variable speed drives on pumps/fans provide a "Soft" start, extending equipment life. Variable speed systems are Quieter than constant speed systems.

ECM 5: Chilled Beams:

Chilled beams do not require a secondary fan so they are inherently more energy efficient

than fan coil units, their main air terminal device rivals. On top of this, chilled beams use higher chilled water flow temperatures than fan coil units (around 14°C), which means there is a significant part of the year when chillers do not need to be working and free cooling is available. The net result of the above, the chilled beam systems is always **lower energy consumption and operating costs.**

ECM 6: Night Pre Cooling:

Night precooling involves the circulation of cool air within a building during the nighttime hours with the intent of cooling the structure. The cooled structure is then able to serve as a heat sink during the daytime hours, reducing the mechanical cooling required. Night cooling would be applicable when the ambient nighttime temperatures are low enough to provide sufficient opportunity to cool the building structure through ventilation air. It is mainly applicable, a hot, dry environment area. This reduces the energy required to operate a chilled water plant.

ECM 7: Thermal Storage System for Cooling:

Consider a thermal storage system when designing your chiller plant. With a thermal storage system, the idea is to run chiller equipment off-peak and store cooled water or ice, then draw on this cooling during the peak times of the day. These systems take one of three forms: chilled water, ice or a salt-water hybrid of both called a eutectic system.

Specifying which system is based on the availability of space for storage media, cooling load profile, rate schedule and current equipment.

ECM 8: Displacement Ventilation:

With a ceiling supply and return air system, the ventilation effectiveness may be compromised if sufficient mixing does not take place. In this case the ventilation effectiveness will approach 80% or less. In displacement ventilation, conditioned air with a temperature slightly lower than the desired room temperature is supplied horizontally at a low velocity at or near the floor. Returns are located at or near the ceiling. The supply air is spread over the floor and then rises by convection as it picks up the load in the room.

Displacement ventilation does not depend on mixing. Instead, you are literally displacing the stale polluted air and forcing it up and out the return or exhaust grille. In this system, the ventilation effectiveness may actually exceed 100%, and ASHRAE 62-1, 6.2 addendum, indicates a ventilation effectiveness of 1.2 shall be used.

ECM 9: Gas Fired Chillers:

Chilled water systems that use fuel types other than electricity can help offset high electricity prices, whether those high prices are caused by consumption or demand charges. Absorption chillers use thermal energy (rather than electricity) to produce chilled water. This type of system can be thought of when natural gas prices are significantly lower than electric prices. The other option is to go for gas based captive power engine to produce electricity and the waste heat from the gas engine can be used to generate chilled water through heat recovery VAM chillers.

ECM 10: Control Cooling Tower Fans by Sensing Ambient Wet Bulb Temperature:

Control cooling tower fans by sensing ambient wet bulb (wb) temperature. Adjust the setpoint for an approach of about 2°F (controller will measure outside wb and adjust setpoint to 2°F warmer).

(7) Effect of other Building material on HVAC System: The overall installed capacity of HVAC plant for the building will become greatly influenced by the Energy Conservation Measure (ECM) adopted for the building. Other than the above mentioned changes in HVAC, the following strategies in the construction improve the overall energy performance of the building

- Providing High Performance Glass Façades by going for SHGC < 0.19
- Providing adequate insulation on building Wall & Roof to meet ECBC & ASHRAE Standard.
- Adopting Lower Power Density (LPD) for lighting as compared to the recommendation from ECBC & ASHRAE standard.
- Efficient Lighting system & using Solar Energy System - Photovoltaic
- Optimizing the orientation of building
- Providing external & internal Solar shading devices.
- Restricting the Glass Façades to meet the Window to Wall Ratio (WWR) not exceeding 60%
- Water conserving plumbing fixtures
- Grey water Systems
- Rainwater Harvesting
- Daylight harvesting